

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 18:00 on May 21)**

Water Level of the accumulated water (at 16:00 on May 21)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,080 mm (17 mm decrease since 7:00 on May 21)	O.P.+ 2,996 mm (7 mm increase since 7:00 on May 21)	—
	Water level of Turbine Building	O.P.+ 2,771 mm (No change since 7:00 on May 21)	O.P.+ 3,098 mm (17 mm decrease since 7:00 on May 21)	O.P.+ 2,884 mm (7 mm increase since 7:00 on May 21)	O.P.+ 2,861 mm (6 mm increase since 7:00 on May 21)
	Water level of Reactor Building	O.P.+ 4,295 mm (15 mm decrease since 7:00 on May 21)	O.P.+ 3,402 mm (17 mm decrease since 7:00 on May 21)	O.P.+ 3,112 mm (9 mm increase since 7:00 on May 21)	O.P.+ 2,868 mm (8 mm increase since 7:00 on May 21)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,433 mm (Increase from initial level:5,650 mm, 4 mm increase since 7:00 on May 21) O.P.+ 1,605 mm (Increase from initial level:2,331 mm, 7 mm increase since 7:00 on May 21) O.P.+ 4,348 mm (Water level from floor:552 mm, 1 mm increase since 7:00 on May 21)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:10 on May 18)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 17:20 on May 15)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:08 on May 16   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.