

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on May 22)**

Water Level of the accumulated water (at 7:00 on May 22)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,045 mm (35 mm decrease since 16:00 on May 21)	O.P.+ 3,007 mm (11 mm increase since 16:00 on May 21)	—
	Water level of Turbine Building	O.P.+ 2,774 mm (3 mm increase since 16:00 on May 21)	O.P.+ 3,067 mm (31 mm decrease since 16:00 on May 21)	O.P.+ 2,896 mm (12 mm increase since 16:00 on May 21)	O.P.+ 2,873 mm (12 mm increase since 16:00 on May 21)
	Water level of Reactor Building	O.P.+ 4,267 mm (28 mm decrease since 16:00 on May 21)	O.P.+ 3,373 mm (29 mm decrease since 16:00 on May 21)	O.P.+ 3,124 mm (12 mm increase since 16:00 on May 21)	O.P.+ 2,877 mm (9 mm increase since 16:00 on May 21)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,435 mm (Increase from initial level:5,652 mm, 2 mm increase since 16:00 on May 21) O.P.+ 1,617 mm (Increase from initial level:2,343 mm, 12 mm increase since 16:00 on May 21) O.P.+ 4,348 mm (Water level from floor:552 mm, No change since 16:00 on May 21)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:10 on May 18)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 17:20 on May 15)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:08 on May 16 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.