

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 18:00 on May 22)**

Water Level of the accumulated water (at 16:00 on May 22)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,026 mm (19 mm decrease since 7:00 on May 22)	O.P.+ 3,013 mm (6 mm increase since 7:00 on May 22)	—
	Water level of Turbine Building	O.P.+ 2,771 mm (3 mm decrease since 7:00 on May 22)	O.P.+ 3,053 mm (14 mm decrease since 7:00 on May 22)	O.P.+ 2,902 mm (6 mm increase since 7:00 on May 22)	O.P.+ 2,879 mm (6 mm increase since 7:00 on May 22)
	Water level of Reactor Building	O.P.+ 4,250 mm (17 mm decrease since 7:00 on May 22)	O.P.+ 3,357 mm (16 mm decrease since 7:00 on May 22)	O.P.+ 3,133 mm (9 mm increase since 7:00 on May 22)	O.P.+ 2,883 mm (6 mm increase since 7:00 on May 22)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,437 mm (Increase from initial level:5,654 mm, 2 mm increase since 7:00 on May 22) O.P.+ 1,628 mm (Increase from initial level:2,354 mm, 11 mm increase since 7:00 on May 22) O.P.+ 4,347 mm (Water level from floor:551 mm, 1 mm decrease since 7:00 on May 22)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:10 on May 18)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 17:20 on May 15)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:08 on May 16   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.