

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on May 23)**

Water Level of the accumulated water (at 7:00 on May 23)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,993 mm (33 mm decrease since 16:00 on May 22)	O.P.+ 3,023 mm (10 mm increase since 16:00 on May 22)	—
	Water level of Turbine Building	O.P.+ 2,772 mm (1 mm increase since 16:00 on May 22)	O.P.+ 3,024 mm (29 mm decrease since 16:00 on May 22)	O.P.+ 2,913 mm (11 mm increase since 16:00 on May 22)	O.P.+ 2,888 mm (9 mm increase since 16:00 on May 22)
	Water level of Reactor Building	O.P.+ 4,224 mm (26 mm decrease since 16:00 on May 22)	O.P.+ 3,329 mm (28 mm decrease since 16:00 on May 22)	O.P.+ 3,144 mm (11 mm increase since 16:00 on May 22)	O.P.+ 2,891 mm (8 mm increase since 16:00 on May 22)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,440 mm (Increase from initial level:5,657 mm, 3 mm increase since 16:00 on May 22) O.P.+ 1,641 mm (Increase from initial level:2,367 mm, 13 mm increase since 16:00 on May 22) O.P.+ 4,348 mm (Water level from floor:552 mm, 1 mm increase since 16:00 on May 22)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:10 on May 18)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 17:20 on May 15)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 7:25 on May 23   Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	At 7:25 AM on May 23, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning.				

※ For quick publication of the data of water level, values are provided as reference values.