

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on May 23)**

Water Level of the accumulated water (at 16:00 on May 23)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,975 mm (18 mm decrease since 7:00 on May 23)	O.P.+ 3,030 mm (7 mm increase since 7:00 on May 23)	—
	Water level of Turbine Building	O.P.+ 2,773 mm (1 mm increase since 7:00 on May 23)	O.P.+ 3,008 mm (16 mm decrease since 7:00 on May 23)	O.P.+ 2,920 mm (7 mm increase since 7:00 on May 23)	O.P.+ 2,895 mm (7 mm increase since 7:00 on May 23)
	Water level of Reactor Building	O.P.+ 4,207 mm (17 mm decrease since 7:00 on May 23)	O.P.+ 3,315 mm (14 mm decrease since 7:00 on May 23)	O.P.+ 3,152 mm (8 mm increase since 7:00 on May 23)	O.P.+ 2,898 mm (7 mm increase since 7:00 on May 23)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,441 mm (Increase from initial level:5,658 mm, 1 mm increase since 7:00 on May 23) O.P.+ 1,946 mm (Increase from initial level:2,672 mm, 305 mm increase since 7:00 on May 23) O.P.+ 4,348 mm (Water level from floor:552 mm, No change since 7:00 on May 23)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:10 on May 18)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 17:20 on May 15)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:30 on May 23 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	*The operation of the second sesium absorption apparatus (SARRY) was suspended at 7:25 on May 23 to wash the filter. Since the work was completed, the operation was started at 16:42 and reached constant flow at 17:30 on the same day.				

For quick publication of the data of water level, values are provided as reference values.