

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on May 24)**

Water Level of the accumulated water (at 7:00 on May 24)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,043 mm * (68 mm increase since 16:00 on May 23)	O.P.+ 3,039 mm (9 mm increase since 16:00 on May 23)	—
	Water level of Turbine Building	O.P.+ 2,773 mm (No change since 16:00 on May 23)	O.P.+ 2,980 mm (28 mm decrease since 16:00 on May 23)	O.P.+ 2,931 mm (11 mm increase since 16:00 on May 23)	O.P.+ 2,905 mm (10 mm increase since 16:00 on May 23)
	Water level of Reactor Building	O.P.+ 4,183 mm (24 mm decrease since 16:00 on May 23)	O.P.+ 3,288 mm (27 mm decrease since 16:00 on May 23)	O.P.+ 3,163 mm (11 mm increase since 16:00 on May 23)	O.P.+ 2,909 mm (11 mm increase since 16:00 on May 23)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,443 mm (Increase from initial level:5,660 mm, 2 mm increase since 16:00 on May 23) O.P.+ 1,946 mm (Increase from initial level:2,672 mm, No change since 16:00 on May 23) O.P.+ 4,349 mm (Water level from floor:553 mm, 1 mm increase since 16:00 on May 23)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:10 on May 18)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 17:20 on May 15)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:30 on May 23 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	- As for the water level of the vertical shaft at Unit 2, we have stopped adjusting -100mm since 7:00 AM on May 24, 2013.				

※ For quick publication of the data of water level, values are provided as reference values.