

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on May 24)**

Water Level of the accumulated water (at 16:00 on May 24)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,062 mm (19 mm increase since 7:00 on May 24)	O.P.+ 3,028 mm (11 mm decrease since 7:00 on May 24)	—
	Water level of Turbine Building	O.P.+ 2,776 mm (3 mm increase since 7:00 on May 24)	O.P.+ 2,998 mm (18 mm increase since 7:00 on May 24)	O.P.+ 2,911 mm (20 mm decrease since 7:00 on May 24)	O.P.+ 2,909 mm (4 mm increase since 7:00 on May 24)
	Water level of Reactor Building	O.P.+ 4,170 mm (13 mm decrease since 7:00 on May 24)	O.P.+ 3,287 mm (1 mm decrease since 7:00 on May 24)	O.P.+ 3,147 mm (16 mm decrease since 7:00 on May 24)	O.P.+ 2,914 mm (5 mm increase since 7:00 on May 24)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,444 mm (Increase from initial level:5,661 mm, 1 mm increase since 7:00 on May 24) O.P.+ 1,932 mm (Increase from initial level:2,658 mm, 14 mm decrease since 7:00 on May 24) O.P.+ 4,349 mm (Water level from floor:553 mm, No change since 7:00 on May 24)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Transfer Completed (From 10:10 on May 18 to 9:30 on May 24)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 17:20 on May 15)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:30 on May 23 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.