

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on May 28)**

Water Level of the accumulated water (at 7:00 on May 28)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,303 mm (36 mm increase since 16:00 on May 27)	O.P.+ 2,939 mm (15 mm decrease since 16:00 on May 27)	—
	Water level of Turbine Building	O.P.+ 2,781 mm (6 mm increase since 16:00 on May 27)	O.P.+ 3,205 mm (32 mm increase since 16:00 on May 27)	O.P.+ 2,778 mm (19 mm decrease since 16:00 on May 27)	O.P.+ 2,825 mm (15 mm decrease since 16:00 on May 27)
	Water level of Reactor Building	O.P.+ 4,189 mm (23 mm increase since 16:00 on May 27)	O.P.+ 3,493 mm (32 mm increase since 16:00 on May 27)	O.P.+ 3,007 mm (18 mm decrease since 16:00 on May 27)	O.P.+ 2,839 mm (15 mm decrease since 16:00 on May 27)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,457 mm (Increase from initial level:5,674 mm, 2 mm increase since 16:00 on May 27) O.P.+ 1,832 mm (Increase from initial level:2,558 mm, 16 mm decrease since 16:00 on May 27) O.P.+ 4,351 mm (Water level from floor:555 mm, 1 mm increase since 16:00 on May 27)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 17:20 on May 15)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:23 on May 28 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	- At 8:23 AM on May 28, we stopped the second Cesium Adsorption Apparatus (SARRY) since we are less able to monitor a water level of the treated water receiving tank due to the software modification.				

※ For quick publication of the data of water level, values are provided as reference values.