

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 18:00 on May 28)**

Water Level of the accumulated water (at 16:00 on May 28)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,311 mm (8 mm increase since 7:00 on May 28)	O.P.+ 2,931 mm (8 mm decrease since 7:00 on May 28)	—
	Water level of Turbine Building	O.P.+ 2,785 mm (4 mm increase since 7:00 on May 28)	O.P.+ 3,211 mm (6 mm increase since 7:00 on May 28)	O.P.+ 2,782 mm (4 mm increase since 7:00 on May 28)	O.P.+ 2,815 mm (10 mm decrease since 7:00 on May 28)
	Water level of Reactor Building	O.P.+ 4,204 mm (15 mm increase since 7:00 on May 28)	O.P.+ 3,508 mm (15 mm increase since 7:00 on May 28)	O.P.+ 3,007 mm (No change since 7:00 on May 28)	O.P.+ 2,832 mm (7 mm decrease since 7:00 on May 28)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,459 mm (Increase from initial level:5,676 mm, 2 mm increase since 7:00 on May 28) O.P.+ 2,028 mm (Increase from initial level:2,754 mm, 196 mm increase since 7:00 on May 28) O.P.+ 4,351 mm (Water level from floor:555 mm, No change since 7:00 on May 28)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 13:44 on May 28)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 17:20 on May 15)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 14:16 on May 28   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	* At 8:23 on May 28, we stopped the 2nd Cesium Absorption Apparatus (SARRY) since the water level of the tank which accept the treated water could not be observed due to a software improvement for tank water level. At 14:16, we confirmed the normal flow.				

※ For quick publication of the data of water level, values are provided as reference values.