

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on May 29)**

Water Level of the accumulated water (at 7:00 on May 29)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,261 mm (50 mm decrease since 16:00 on May 28)	O.P.+ 2,936 mm (5 mm increase since 16:00 on May 28)	—
	Water level of Turbine Building	O.P.+ 2,780 mm (5 mm decrease since 16:00 on May 28)	O.P.+ 3,189 mm (22 mm decrease since 16:00 on May 28)	O.P.+ 2,817 mm (35 mm increase since 16:00 on May 28)	O.P.+ 2,809 mm (6 mm decrease since 16:00 on May 28)
	Water level of Reactor Building	O.P.+ 4,222 mm (18 mm increase since 16:00 on May 28)	O.P.+ 3,474 mm (34 mm decrease since 16:00 on May 28)	O.P.+ 3,044 mm (37 mm increase since 16:00 on May 28)	O.P.+ 2,823 mm (9 mm decrease since 16:00 on May 28)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,461 mm (Increase from initial level:5,678 mm, 2 mm increase since 16:00 on May 28) O.P.+ 2,000 mm (Increase from initial level:2,726 mm, 28 mm decrease since 16:00 on May 28) O.P.+ 4,351 mm (Water level from floor:555 mm, No change since 16:00 on May 28)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 13:44 on May 28)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 17:20 on May 15)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 14:16 on May 28 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.