

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on May 30)**

Water Level of the accumulated water (at 7:00 on May 30)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,195 mm (41 mm decrease since 16:00 on May 29)	O.P.+ 2,956 mm (13 mm increase since 16:00 on May 29)	—
	Water level of Turbine Building	O.P.+ 2,785 mm (4 mm increase since 16:00 on May 29)	O.P.+ 3,112 mm (34 mm decrease since 16:00 on May 29)	O.P.+ 2,839 mm (13 mm increase since 16:00 on May 29)	O.P.+ 2,823 mm (10 mm increase since 16:00 on May 29)
	Water level of Reactor Building	O.P.+ 4,220 mm (2 mm decrease since 16:00 on May 29)	O.P.+ 3,420 mm (33 mm decrease since 16:00 on May 29)	O.P.+ 3,070 mm (16 mm increase since 16:00 on May 29)	O.P.+ 2,834 mm (8 mm increase since 16:00 on May 29)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,466 mm (Increase from initial level:5,683 mm, 4 mm increase since 16:00 on May 29) O.P.+ 1,960 mm (Increase from initial level:2,686 mm, 25 mm decrease since 16:00 on May 29) O.P.+ 4,351 mm (Water level from floor:555 mm, No change since 16:00 on May 29)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 13:44 on May 28)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 17:20 on May 15)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 14:16 on May 28 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.