

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on May 31)**

Water Level of the accumulated water (at 7:00 on May 31)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,142 mm (31 mm decrease since 16:00 on May 30)	O.P.+ 2,982 mm (20 mm increase since 16:00 on May 30)	—
	Water level of Turbine Building	O.P.+ 2,789 mm (4 mm increase since 16:00 on May 30)	O.P.+ 3,067 mm (25 mm decrease since 16:00 on May 30)	O.P.+ 2,870 mm (23 mm increase since 16:00 on May 30)	O.P.+ 2,845 mm (16 mm increase since 16:00 on May 30)
	Water level of Reactor Building	O.P.+ 4,292 mm (76 mm increase since 16:00 on May 30)	O.P.+ 3,385 mm (17 mm decrease since 16:00 on May 30)	O.P.+ 3,106 mm (15 mm increase since 16:00 on May 30)	O.P.+ 2,854 mm (14 mm increase since 16:00 on May 30)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,468 mm (Increase from initial level:5,685 mm, 1 mm increase since 16:00 on May 30) O.P.+ 1,920 mm (Increase from initial level:2,646 mm, 25 mm decrease since 16:00 on May 30) O.P.+ 4,351 mm (Water level from floor:555 mm, No change since 16:00 on May 30)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 13:44 on May 28)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 17:20 on May 15)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 14:16 on May 28 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.