

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on June 3)**

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 16:00 on June 3)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,015 mm (22 mm increase since 7:00 on June 3)	O.P.+ 3,026 mm (11 mm decrease since 7:00 on June 3)	—
	Water level of Turbine Building	O.P.+ 2,790 mm (3 mm decrease since 7:00 on June 3)	O.P.+ 2,959 mm (19 mm increase since 7:00 on June 3)	O.P.+ 2,904 mm (21 mm decrease since 7:00 on June 3)	O.P.+ 2,904 mm (4 mm increase since 7:00 on June 3)
	Water level of Reactor Building	O.P.+ 4,259 mm (21 mm decrease since 7:00 on June 3)	O.P.+ 3,255 mm (No change since 7:00 on June 3)	O.P.+ 3,147 mm (16 mm decrease since 7:00 on June 3)	O.P.+ 2,909 mm (6 mm increase since 7:00 on June 3)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,481 mm (Increase from initial level:5,698 mm, 1 mm increase since 7:00 on June 3) O.P.+ 1,812 mm (Increase from initial level:2,538 mm, 10 mm decrease since 7:00 on June 3) O.P.+ 4,353 mm (Water level from floor:557 mm, No change since 7:00 on June 3)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Transfer Completed (From 13:44 on May 28 to 9:35 on June 3)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 17:20 on May 15)	—
		Unit 5 and 6 —			
Operation condition of water treatment facility	Cesium Adsorption Apparatus: Since 9:28 on March 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 14:16 on May 28 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance				
Notes					

※ For quick publication of the data of water level, values are provided as reference values.