## Situation of water level, transfer and treatment of the accumulated water in Fukushima Daiichi Nuclear Power Station (at 9:00 on June 4)

|  |  | Unit 1  | Unit 2  | Unit 3   | Unit 4  |
|--|--|---|---|--|---|
| Water Level of the<br>accumulated water<br>(at 7:00 on June 4) | Water level<br>of Vertical Shaft   | Unmeasurable due to drawdown of<br>water level<br>(Less than O.P.+ 850 mm)  | O.P.+ 3,067 mm<br>(52 mm increase since 16:00 on<br>June 3)                                 | O.P.+ 3,016 mm<br>(10 mm decrease since 16:00 on<br>June 3)  | _   |
|  | Water level of Turbine Building  | O.P.+ 2,794 mm<br>(4 mm increase since 16:00 on June<br>3)  | O.P.+ 3,002 mm<br>(43 mm increase since 16:00 on<br>June 3)                                 | O.P.+ 2,873 mm<br>(31 mm decrease since 16:00 on<br>June 3)  | O.P.+ 2,894 mm<br>(10 mm decrease since 16:00 on<br>June 3) |
|  | Water level of Reactor Building  | O.P.+ 4,235 mm<br>(24 mm decrease since 16:00 on<br>June 3)   | O.P.+ 3,294 mm<br>(39 mm increase since 16:00 on<br>June 3)                                 | O.P.+ 3,113 mm<br>(34 mm decrease since 16:00 on<br>June 3)  | O.P.+ 2,903 mm<br>(6 mm decrease since 16:00 on June<br>3)  |
|  | Water level<br>of each building<br>in the Centralized<br>Radiation Waste<br>Treatment Facility | Process Main Building   | O.P.+ 4,484 mm (Increase from initial level:5,701 mm, 3 mm increase since 16:00 on June 3)  |  |   |
|  |  | High Temperature<br>Incinerator Building  | O.P.+ 1,793 mm (Increase from initial level:2,519 mm, 19 mm decrease since 16:00 on June 3) |  |   |
|  |  | On-site Bunker Building   | O.P.+ 4,353 mm (Water level from floor:557 mm, No change since 16:00 on June 3)             |  |   |
| Situation of transfer of the accumulated water                 |  | Unit 1  | Unit 2  | Unit 3   | Unit 4  |
|  |  | _   | _   | Basement of Unit 3 Turbine Building<br>→Centralized Radiation Waste<br>Treatment Facility (High<br>Temperature Incinerator Building)<br>Currently being transferred<br>(Since 17:20 on May 15) | _   |
|  |  | Unit 5 and 6  |   |  |   |
|  |  | _   |   |  |   |
| Operation condition of water treatment facility                |  | Cesium Adsorption Apparatus: Since 9:28 on March 21 Suspended<br>2nd Cesium Adsorption Apparatus (Sarry): Since 14:16 on May 28 In operation<br>Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance<br>Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance |   |  |   |
| Notes  |  |   |   |  |   |

% For quick publication of the data of water level, values are provided as reference values.