

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on June 4)**

| | | | | | |
|--|--|---|---|--|--|
| Water Level of the accumulated water (at 16:00 on June 4) | | Unit 1 | Unit 2 | Unit 3 | Unit 4 |
| | Water level of Vertical Shaft | Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm) | O.P.+ 3,095 mm (28 mm increase since 7:00 on June 4) | O.P.+ 3,005 mm (11 mm decrease since 7:00 on June 4) | — |
| | Water level of Turbine Building | O.P.+ 2,797 mm (3 mm increase since 7:00 on June 4) | O.P.+ 3,028 mm (26 mm increase since 7:00 on June 4) | O.P.+ 2,858 mm (15 mm decrease since 7:00 on June 4) | O.P.+ 2,887 mm (7 mm decrease since 7:00 on June 4) |
| | Water level of Reactor Building | O.P.+ 4,227 mm (8 mm decrease since 7:00 on June 4) | O.P.+ 3,320 mm (26 mm increase since 7:00 on June 4) | O.P.+ 3,096 mm (17 mm decrease since 7:00 on June 4) | O.P.+ 2,896 mm (7 mm decrease since 7:00 on June 4) |
| | Water level of each building in the Centralized Radiation Waste Treatment Facility | Process Main Building High Temperature Incinerator Building On-site Bunker Building | O.P.+ 4,485 mm (Increase from initial level:5,702 mm, 1 mm increase since 7:00 on June 4) O.P.+ 1,782 mm (Increase from initial level:2,508 mm, 11 mm decrease since 7:00 on June 4) O.P.+ 4,354 mm (Water level from floor:558 mm, 1 mm increase since 7:00 on June 4) | | |
| Situation of transfer of the accumulated water | | Unit 1 | Unit 2 | Unit 3 | Unit 4 |
| | | — | — | Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 17:20 on May 15) | — |
| | | Unit 5 and 6 | | | |
| | | — | | | |
| Operation condition of water treatment facility | | Cesium Adsorption Apparatus: Since 9:28 on March 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 14:16 on May 28 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance | | | |
| Notes | | | | | |

※ For quick publication of the data of water level, values are provided as reference values.