

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on June 6)**

Water Level of the accumulated water (at 7:00 on June 6)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,208 mm (43 mm increase since 16:00 on June 5)	O.P.+ 2,966 mm (15 mm decrease since 16:00 on June 5)	—
	Water level of Turbine Building	O.P.+ 2,799 mm (1 mm increase since 16:00 on June 5)	O.P.+ 3,121 mm (35 mm increase since 16:00 on June 5)	O.P.+ 2,807 mm (17 mm decrease since 16:00 on June 5)	O.P.+ 2,848 mm (15 mm decrease since 16:00 on June 5)
	Water level of Reactor Building	O.P.+ 4,197 mm (3 mm decrease since 16:00 on June 5)	O.P.+ 3,413 mm (37 mm increase since 16:00 on June 5)	O.P.+ 3,038 mm (21 mm decrease since 16:00 on June 5)	O.P.+ 2,860 mm (14 mm decrease since 16:00 on June 5)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,491 mm (Increase from initial level:5,708 mm, 2 mm increase since 16:00 on June 5) O.P.+ 1,745 mm (Increase from initial level:2,471 mm, 13 mm decrease since 16:00 on June 5) O.P.+ 4,354 mm (Water level from floor:558 mm, No change since 16:00 on June 5)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 17:20 on May 15)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:23 on June 6 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	- At 8:23 AM on June 6, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning.				

※ For quick publication of the data of water level, values are provided as reference values.