

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on June 6)**

Water Level of the accumulated water (at 16:00 on June 6)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,232 mm (24 mm increase since 7:00 on June 6)	O.P.+ 2,957 mm (9 mm decrease since 7:00 on June 6)	—
	Water level of Turbine Building	O.P.+ 2,800 mm (1 mm increase since 7:00 on June 6)	O.P.+ 3,145 mm (24 mm increase since 7:00 on June 6)	O.P.+ 2,795 mm (12 mm decrease since 7:00 on June 6)	O.P.+ 2,838 mm (10 mm decrease since 7:00 on June 6)
	Water level of Reactor Building	O.P.+ 4,201 mm (4 mm increase since 7:00 on June 6)	O.P.+ 3,434 mm (21 mm increase since 7:00 on June 6)	O.P.+ 3,027 mm (11 mm decrease since 7:00 on June 6)	O.P.+ 2,851 mm (9 mm decrease since 7:00 on June 6)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,493 mm (Increase from initial level:5,710 mm, 2 mm increase since 7:00 on June 6) O.P.+ 1,840 mm (Increase from initial level:2,566 mm, 95 mm increase since 7:00 on June 6) O.P.+ 4,354 mm (Water level from floor:558 mm, No change since 7:00 on June 6)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 17:20 on May 15)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 11:59 on June 6 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	At 8:23 AM on June 6, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning. At 11:06 AM on the same day, the apparatus was restarted after the filter cleaning, and the steady flow rate was achieved at 11:59 AM on the same day.				

※ For quick publication of the data of water level, values are provided as reference values.