

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 18:00 on June 7)**

Water Level of the accumulated water (at 16:00 on June 7)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,295 mm (24 mm increase since 7:00 on June 7)	O.P.+ 2,933 mm (9 mm decrease since 7:00 on June 7)	—
	Water level of Turbine Building	O.P.+ 2,801 mm (1 mm increase since 7:00 on June 7)	O.P.+ 3,197 mm (19 mm increase since 7:00 on June 7)	O.P.+ 2,779 mm (2 mm increase since 7:00 on June 7)	O.P.+ 2,813 mm (9 mm decrease since 7:00 on June 7)
	Water level of Reactor Building	O.P.+ 4,223 mm (10 mm increase since 7:00 on June 7)	O.P.+ 3,489 mm (20 mm increase since 7:00 on June 7)	O.P.+ 3,005 mm (1 mm decrease since 7:00 on June 7)	O.P.+ 2,828 mm (9 mm decrease since 7:00 on June 7)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,497 mm (Increase from initial level:5,714 mm, 4 mm increase since 7:00 on June 7) O.P.+ 1,745 mm (Increase from initial level:2,471 mm, 72 mm decrease since 7:00 on June 7) O.P.+ 4,354 mm (Water level from floor:558 mm, No change since 7:00 on June 7)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 12:02 on June 7)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 11:59 on June 6   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.