

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on June 10)**

Water Level of the accumulated water (at 16:00 on June 10)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,180 mm (24 mm decrease since 7:00 on June 10)	O.P.+ 2,951 mm (7 mm increase since 7:00 on June 10)	—
	Water level of Turbine Building	O.P.+ 2,805 mm (No change since 7:00 on June 10)	O.P.+ 3,100 mm (20 mm decrease since 7:00 on June 10)	O.P.+ 2,834 mm (8 mm increase since 7:00 on June 10)	O.P.+ 2,811 mm (6 mm increase since 7:00 on June 10)
	Water level of Reactor Building	O.P.+ 4,254 mm (7 mm decrease since 7:00 on June 10)	O.P.+ 3,413 mm (17 mm decrease since 7:00 on June 10)	O.P.+ 3,061 mm (7 mm increase since 7:00 on June 10)	O.P.+ 2,822 mm (6 mm increase since 7:00 on June 10)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,509 mm (Increase from initial level:5,726 mm, 2 mm increase since 7:00 on June 10) O.P.+ 1,652 mm (Increase from initial level:2,378 mm, 11 mm decrease since 7:00 on June 10) O.P.+ 4,356 mm (Water level from floor:560 mm, No change since 7:00 on June 10)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 9:55 on June 8)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 12:02 on June 7)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 11:59 on June 6 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.