

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on June 12)**

Water Level of the accumulated water (at 16:00 on June 12)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,067 mm (21 mm decrease since 7:00 on June 12)	O.P.+ 2,984 mm (4 mm increase since 7:00 on June 12)	—
	Water level of Turbine Building	O.P.+ 2,805 mm (No change since 7:00 on June 12)	O.P.+ 3,003 mm (18 mm decrease since 7:00 on June 12)	O.P.+ 2,869 mm (6 mm increase since 7:00 on June 12)	O.P.+ 2,845 mm (6 mm increase since 7:00 on June 12)
	Water level of Reactor Building	O.P.+ 4,174 mm (17 mm decrease since 7:00 on June 12)	O.P.+ 3,316 mm (16 mm decrease since 7:00 on June 12)	O.P.+ 3,099 mm (6 mm increase since 7:00 on June 12)	O.P.+ 2,851 mm (5 mm increase since 7:00 on June 12)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,515 mm (Increase from initial level:5,732 mm, 1 mm increase since 7:00 on June 12) O.P.+ 1,603 mm (Increase from initial level:2,329 mm, 6 mm decrease since 7:00 on June 12) O.P.+ 4,357 mm (Water level from floor:561 mm, No change since 7:00 on June 12)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 9:55 on June 8)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 12:02 on June 7)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 11:59 on June 6 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.