

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on June 13)**

Water Level of the accumulated water (at 7:00 on June 13)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,033 mm (34 mm decrease since 16:00 on June 12)	O.P.+ 2,995 mm (11 mm increase since 16:00 on June 12)	—
	Water level of Turbine Building	O.P.+ 2,806 mm (1 mm increase since 16:00 on June 12)	O.P.+ 2,974 mm (29 mm decrease since 16:00 on June 12)	O.P.+ 2,880 mm (11 mm increase since 16:00 on June 12)	O.P.+ 2,855 mm (10 mm increase since 16:00 on June 12)
	Water level of Reactor Building	O.P.+ 4,149 mm (25 mm decrease since 16:00 on June 12)	O.P.+ 3,287 mm (29 mm decrease since 16:00 on June 12)	O.P.+ 3,111 mm (12 mm increase since 16:00 on June 12)	O.P.+ 2,860 mm (9 mm increase since 16:00 on June 12)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,518 mm (Increase from initial level:5,735 mm, 3 mm increase since 16:00 on June 12) O.P.+ 1,589 mm (Increase from initial level:2,315 mm, 14 mm decrease since 16:00 on June 12) O.P.+ 4,357 mm (Water level from floor:561 mm, No change since 16:00 on June 12)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 9:55 on June 8)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 12:02 on June 7)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:28 on June 13   Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	At 8:28 AM on June 13, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning.				

※ For quick publication of the data of water level, values are provided as reference values.