

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on June 13)**

Water Level of the accumulated water (at 16:00 on June 13)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,013 mm (20 mm decrease since 7:00 on June 13)	O.P.+ 3,001 mm (6 mm increase since 7:00 on June 13)	—
	Water level of Turbine Building	O.P.+ 2,806 mm (No change since 7:00 on June 13)	O.P.+ 2,956 mm (18 mm decrease since 7:00 on June 13)	O.P.+ 2,885 mm (5 mm increase since 7:00 on June 13)	O.P.+ 2,861 mm (6 mm increase since 7:00 on June 13)
	Water level of Reactor Building	O.P.+ 4,135 mm (14 mm decrease since 7:00 on June 13)	O.P.+ 3,271 mm (16 mm decrease since 7:00 on June 13)	O.P.+ 3,119 mm (8 mm increase since 7:00 on June 13)	O.P.+ 2,866 mm (6 mm increase since 7:00 on June 13)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,519 mm (Increase from initial level:5,736 mm, 1 mm increase since 7:00 on June 13) O.P.+ 1,757 mm (Increase from initial level:2,483 mm, 168 mm increase since 7:00 on June 13) O.P.+ 4,357 mm (Water level from floor:561 mm, No change since 7:00 on June 13)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 9:55 on June 8)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 12:02 on June 7)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:27 on June 13 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	At 8:28 AM on June 13, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning. At 0:52 PM on the same day, the apparatus was restarted after the filter cleaning, and the steady flow rate was achieved at 1:27 PM on the same day.				

For quick publication of the data of water level, values are provided as reference values.