

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on June 17)**

Water Level of the accumulated water (at 7:00 on June 17)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,191 mm (42 mm increase since 16:00 on June 16)	O.P.+ 2,947 mm (13 mm decrease since 16:00 on June 16)	—
	Water level of Turbine Building	O.P.+ 2,813 mm (2 mm increase since 16:00 on June 16)	O.P.+ 3,109 mm (35 mm increase since 16:00 on June 16)	O.P.+ 2,783 mm (17 mm decrease since 16:00 on June 16)	O.P.+ 2,823 mm (15 mm decrease since 16:00 on June 16)
	Water level of Reactor Building	O.P.+ 4,233 mm (45 mm increase since 16:00 on June 16)	O.P.+ 3,404 mm (33 mm increase since 16:00 on June 16)	O.P.+ 2,962 mm (68 mm decrease since 16:00 on June 16)	O.P.+ 2,839 mm (13 mm decrease since 16:00 on June 16)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,533 mm (Increase from initial level:5,750 mm, 3 mm increase since 16:00 on June 16) O.P.+ 1,633 mm (Increase from initial level:2,359 mm, 20 mm decrease since 16:00 on June 16) O.P.+ 4,359 mm (Water level from floor:563 mm, No change since 16:00 on June 16)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 12:02 on June 7)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:27 on June 13 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.