## Situation of water level, transfer and treatment of the accumulated water in Fukushima Daiichi Nuclear Power Station (at 18:00 on June 17)

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 16:00 on June 17)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,215 mm (24 mm increase since 7:00 on June 17)	O.P.+ 2,935 mm (12 mm decrease since 7:00 on June 17)	_
	Water level of Turbine Building	O.P.+ 2,814 mm (1 mm increase since 7:00 on June 17)	O.P.+ 3,130 mm (21 mm increase since 7:00 on June 17)	O.P.+ 2,774 mm (9 mm decrease since 7:00 on June 17)	O.P.+ 2,814 mm (9 mm decrease since 7:00 on June 17)
	Water level of Reactor Building	O.P.+ 4,255 mm (22 mm increase since 7:00 on June 17)	O.P.+ 3,426 mm (22 mm increase since 7:00 on June 17)	O.P.+ 2,992 mm (30 mm increase since 7:00 on June 17)	O.P.+ 2,829 mm (10 mm decrease since 7:00 on June 17)
	Water level	Process Main Building	O.P.+ 4,535 mm (Increase from initial level:5,752 mm, 2 mm increase since 7:00 on June 17)		
	of each building in the Centralized Radiation Waste Treatment Facility	High Temperature Incinerator Building	O.P.+ 1,622 mm (Increase from initial level:2,348 mm, 11 mm decrease since 7:00 on June 17)		
		On-site Bunker Building	O.P.+ 4,360 mm (Water level from floor:564 mm, 1 mm increase since 7:00 on June 17)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		_	_	Basement of Unit 3 Turbine Building  →Centralized Radiation Waste  Treatment Facility (High  Temperature Incinerator Building)  Currently being transferred  (Since 12:02 on June 7)	_
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:27 on June 13 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					
			For a	uick publication of the data of water level.	values are provided as reference values