

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on June 18)**

| | | | | | |
|--|--|--|---|---|---|
| Water Level of the accumulated water (at 7:00 on June 18) | | Unit 1 | Unit 2 | Unit 3 | Unit 4 |
| | Water level of Vertical Shaft | Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm) | O.P.+ 3,253 mm (38 mm increase since 16:00 on June 17) | O.P.+ 2,920 mm (15 mm decrease since 16:00 on June 17) | — |
| | Water level of Turbine Building | O.P.+ 2,814 mm (No change since 16:00 on June 17) | O.P.+ 3,164 mm (34 mm increase since 16:00 on June 17) | O.P.+ 2,754 mm (20 mm decrease since 16:00 on June 17) | O.P.+ 2,798 mm (16 mm decrease since 16:00 on June 17) |
| | Water level of Reactor Building | O.P.+ 4,285 mm (30 mm increase since 16:00 on June 17) | O.P.+ 3,458 mm (32 mm increase since 16:00 on June 17) | O.P.+ 2,972 mm (20 mm decrease since 16:00 on June 17) | O.P.+ 2,815 mm (14 mm decrease since 16:00 on June 17) |
| | Water level of each building in the Centralized Radiation Waste Treatment Facility | Process Main Building High Temperature Incinerator Building On-site Bunker Building | O.P.+ 4,538 mm (Increase from initial level:5,755 mm, 3 mm increase since 16:00 on June 17) O.P.+ 1,602 mm (Increase from initial level:2,328 mm, 20 mm decrease since 16:00 on June 17) O.P.+ 4,360 mm (Water level from floor:564 mm, No change since 16:00 on June 17) | | |
| Situation of transfer of the accumulated water | | Unit 1 | Unit 2 | Unit 3 | Unit 4 |
| | | — | — | Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 12:02 on June 7) | — |
| | | Unit 5 and 6 | | | |
| | | — | | | |
| Operation condition of water treatment facility | | Cesium Adsorption Apparatus: Since 9:28 on March 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:27 on June 13 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance | | | |
| Notes | | | | | |

※ For quick publication of the data of water level, values are provided as reference values.