

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on June 19)**

Water Level of the accumulated water (at 7:00 on June 19)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,315 mm (40 mm increase since 16:00 on June 18)	O.P.+ 2,894 mm (16 mm decrease since 16:00 on June 18)	—
	Water level of Turbine Building	O.P.+ 2,816 mm (1 mm increase since 16:00 on June 18)	O.P.+ 3,216 mm (33 mm increase since 16:00 on June 18)	O.P.+ 2,722 mm (20 mm decrease since 16:00 on June 18)	O.P.+ 2,775 mm (15 mm decrease since 16:00 on June 18)
	Water level of Reactor Building	O.P.+ 4,326 mm (26 mm increase since 16:00 on June 18)	O.P.+ 3,513 mm (34 mm increase since 16:00 on June 18)	O.P.+ 2,945 mm (19 mm decrease since 16:00 on June 18)	O.P.+ 2,793 mm (13 mm decrease since 16:00 on June 18)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,541 mm (Increase from initial level:5,758 mm, 3 mm increase since 16:00 on June 18) O.P.+ 1,575 mm (Increase from initial level:2,301 mm, 18 mm decrease since 16:00 on June 18) O.P.+ 4,361 mm (Water level from floor:565 mm, 1 mm increase since 16:00 on June 18)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 12:02 on June 7)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:27 on June 13   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.