

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on June 19)**

Water Level of the accumulated water (at 16:00 on June 19)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,299 mm (16 mm decrease since 7:00 on June 19)	O.P.+ 2,891 mm (3 mm decrease since 7:00 on June 19)	—
	Water level of Turbine Building	O.P.+ 2,819 mm (3 mm increase since 7:00 on June 19)	O.P.+ 3,202 mm (14 mm decrease since 7:00 on June 19)	O.P.+ 2,746 mm (24 mm increase since 7:00 on June 19)	O.P.+ 2,767 mm (8 mm decrease since 7:00 on June 19)
	Water level of Reactor Building	O.P.+ 4,361 mm (35 mm increase since 7:00 on June 19)	O.P.+ 3,516 mm (3 mm increase since 7:00 on June 19)	O.P.+ 2,963 mm (18 mm increase since 7:00 on June 19)	O.P.+ 2,786 mm (7 mm decrease since 7:00 on June 19)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,543 mm (Increase from initial level:5,760 mm, 2 mm increase since 7:00 on June 19) O.P.+ 1,567 mm (Increase from initial level:2,293 mm, 8 mm decrease since 7:00 on June 19) O.P.+ 4,361 mm (Water level from floor:565 mm, No change since 7:00 on June 19)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 9:43 on June 19)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 12:02 on June 7)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:27 on June 13 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.