

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on June 20)**

Water Level of the accumulated water (at 7:00 on June 20)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,253 mm (46 mm decrease since 16:00 on June 19)	O.P.+ 2,903 mm (12 mm increase since 16:00 on June 19)	—
	Water level of Turbine Building	O.P.+ 2,820 mm (1 mm increase since 16:00 on June 19)	O.P.+ 3,162 mm (40 mm decrease since 16:00 on June 19)	O.P.+ 2,779 mm (33 mm increase since 16:00 on June 19)	O.P.+ 2,765 mm (2 mm decrease since 16:00 on June 19)
	Water level of Reactor Building	O.P.+ 4,381 mm (20 mm increase since 16:00 on June 19)	O.P.+ 3,475 mm (41 mm decrease since 16:00 on June 19)	O.P.+ 2,997 mm (34 mm increase since 16:00 on June 19)	O.P.+ 2,781 mm (5 mm decrease since 16:00 on June 19)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,545 mm (Increase from initial level:5,762 mm, 2 mm increase since 16:00 on June 19) O.P.+ 1,549 mm (Increase from initial level:2,275 mm, 18 mm decrease since 16:00 on June 19) O.P.+ 4,362 mm (Water level from floor:566 mm, 1 mm increase since 16:00 on June 19)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 9:43 on June 19)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 12:02 on June 7)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:29 on June 20   Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	- At 8:29 AM on June 20, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning.				

※ For quick publication of the data of water level, values are provided as reference values.