

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 18:00 on June 20)**

Water Level of the accumulated water (at 16:00 on June 20)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,228 mm (25 mm decrease since 7:00 on June 20)	O.P.+ 2,911 mm (8 mm increase since 7:00 on June 20)	—
	Water level of Turbine Building	O.P.+ 2,821 mm (1 mm increase since 7:00 on June 20)	O.P.+ 3,141 mm (21 mm decrease since 7:00 on June 20)	O.P.+ 2,787 mm (8 mm increase since 7:00 on June 20)	O.P.+ 2,770 mm (5 mm increase since 7:00 on June 20)
	Water level of Reactor Building	O.P.+ 4,377 mm (4 mm decrease since 7:00 on June 20)	O.P.+ 3,453 mm (22 mm decrease since 7:00 on June 20)	O.P.+ 3,009 mm (12 mm increase since 7:00 on June 20)	O.P.+ 2,784 mm (3 mm increase since 7:00 on June 20)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,546 mm (Increase from initial level:5,763 mm, 1 mm increase since 7:00 on June 20) O.P.+ 1,651 mm (Increase from initial level:2,377 mm, 102 mm increase since 7:00 on June 20) O.P.+ 4,362 mm (Water level from floor:566 mm, No change since 7:00 on June 20)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 9:43 on June 19)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 12:02 on June 7)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 11:48 on June 20   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	At 8:29 AM on June 20, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning. As the cleaning has been completed, we started its operation at 11:34 AM and confirmed its constant flow at 11:48 AM on the same day.				

※ For quick publication of the data of water level, values are provided as reference values.