

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on June 21)**

Water Level of the accumulated water (at 7:00 on June 21)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,187 mm (41 mm decrease since 16:00 on June 20)	O.P.+ 2,924 mm (13 mm increase since 16:00 on June 20)	—
	Water level of Turbine Building	O.P.+ 2,822 mm (1 mm increase since 16:00 on June 20)	O.P.+ 3,108 mm (33 mm decrease since 16:00 on June 20)	O.P.+ 2,799 mm (12 mm increase since 16:00 on June 20)	O.P.+ 2,780 mm (10 mm increase since 16:00 on June 20)
	Water level of Reactor Building	O.P.+ 4,364 mm (13 mm decrease since 16:00 on June 20)	O.P.+ 3,419 mm (34 mm decrease since 16:00 on June 20)	O.P.+ 3,024 mm (15 mm increase since 16:00 on June 20)	O.P.+ 2,792 mm (8 mm increase since 16:00 on June 20)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,550 mm (Increase from initial level:5,767 mm, 4 mm increase since 16:00 on June 20) O.P.+ 1,627 mm (Increase from initial level:2,353 mm, 24 mm decrease since 16:00 on June 20) O.P.+ 4,362 mm (Water level from floor:566 mm, No change since 16:00 on June 20)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 9:43 on June 19)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 12:02 on June 7)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 11:48 on June 20 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.