

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on June 21)**

Water Level of the accumulated water (at 16:00 on June 21)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,166 mm (21 mm decrease since 7:00 on June 21)	O.P.+ 2,930 mm (6 mm increase since 7:00 on June 21)	—
	Water level of Turbine Building	O.P.+ 2,823 mm (1 mm increase since 7:00 on June 21)	O.P.+ 3,088 mm (20 mm decrease since 7:00 on June 21)	O.P.+ 2,809 mm (10 mm increase since 7:00 on June 21)	O.P.+ 2,786 mm (6 mm increase since 7:00 on June 21)
	Water level of Reactor Building	O.P.+ 4,352 mm (12 mm decrease since 7:00 on June 21)	O.P.+ 3,400 mm (19 mm decrease since 7:00 on June 21)	O.P.+ 3,032 mm (8 mm increase since 7:00 on June 21)	O.P.+ 2,796 mm (4 mm increase since 7:00 on June 21)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,551 mm (Increase from initial level:5,768 mm, 1 mm increase since 7:00 on June 21) O.P.+ 1,613 mm (Increase from initial level:2,339 mm, 14 mm decrease since 7:00 on June 21) O.P.+ 4,363 mm (Water level from floor:567 mm, 1 mm increase since 7:00 on June 21)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 9:43 on June 19)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 12:02 on June 7)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 11:48 on June 20 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.