

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on June 24)**

Water Level of the accumulated water (at 7:00 on June 24)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,022 mm (31 mm decrease since 16:00 on June 23)	O.P.+ 2,980 mm (11 mm increase since 16:00 on June 23)	—
	Water level of Turbine Building	O.P.+ 2,834 mm (2 mm increase since 16:00 on June 23)	O.P.+ 2,965 mm (27 mm decrease since 16:00 on June 23)	O.P.+ 2,859 mm (12 mm increase since 16:00 on June 23)	O.P.+ 2,833 mm (11 mm increase since 16:00 on June 23)
	Water level of Reactor Building	O.P.+ 4,314 mm (23 mm decrease since 16:00 on June 23)	O.P.+ 3,279 mm (30 mm decrease since 16:00 on June 23)	O.P.+ 3,090 mm (15 mm increase since 16:00 on June 23)	O.P.+ 2,838 mm (9 mm increase since 16:00 on June 23)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,564 mm (Increase from initial level:5,781 mm, 4 mm increase since 16:00 on June 23) O.P.+ 1,512 mm (Increase from initial level:2,238 mm, 24 mm decrease since 16:00 on June 23) O.P.+ 4,364 mm (Water level from floor:568 mm, No change since 16:00 on June 23)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 9:43 on June 19)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 12:02 on June 7)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 11:48 on June 20 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.