

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on June 25)**

Water Level of the accumulated water (at 7:00 on June 25)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,969 mm (33 mm decrease since 16:00 on June 24)	O.P.+ 2,995 mm (8 mm increase since 16:00 on June 24)	—
	Water level of Turbine Building	O.P.+ 2,839 mm (2 mm increase since 16:00 on June 24)	O.P.+ 2,919 mm (28 mm decrease since 16:00 on June 24)	O.P.+ 2,879 mm (10 mm increase since 16:00 on June 24)	O.P.+ 2,849 mm (10 mm increase since 16:00 on June 24)
	Water level of Reactor Building	O.P.+ 4,275 mm (26 mm decrease since 16:00 on June 24)	O.P.+ 3,235 mm (29 mm decrease since 16:00 on June 24)	O.P.+ 3,110 mm (13 mm increase since 16:00 on June 24)	O.P.+ 2,853 mm (9 mm increase since 16:00 on June 24)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,568 mm (Increase from initial level:5,785 mm, 3 mm increase since 16:00 on June 24) O.P.+ 1,471 mm (Increase from initial level:2,197 mm, 25 mm decrease since 16:00 on June 24) O.P.+ 4,365 mm (Water level from floor:569 mm, No change since 16:00 on June 24)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 9:43 on June 19)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 12:02 on June 7)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 11:48 on June 20 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.