

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 18:00 on June 25)**

Water Level of the accumulated water (at 16:00 on June 25)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,949 mm (20 mm decrease since 7:00 on June 25)	O.P.+ 3,001 mm (6 mm increase since 7:00 on June 25)	—
	Water level of Turbine Building	O.P.+ 2,841 mm (2 mm increase since 7:00 on June 25)	O.P.+ 2,903 mm (16 mm decrease since 7:00 on June 25)	O.P.+ 2,885 mm (6 mm increase since 7:00 on June 25)	O.P.+ 2,855 mm (6 mm increase since 7:00 on June 25)
	Water level of Reactor Building	O.P.+ 4,259 mm (16 mm decrease since 7:00 on June 25)	O.P.+ 3,220 mm (15 mm decrease since 7:00 on June 25)	O.P.+ 3,121 mm (11 mm increase since 7:00 on June 25)	O.P.+ 2,859 mm (6 mm increase since 7:00 on June 25)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,570 mm (Increase from initial level:5,787 mm, 2 mm increase since 7:00 on June 25) O.P.+ 1,455 mm (Increase from initial level:2,181 mm, 16 mm decrease since 7:00 on June 25) O.P.+ 4,366 mm (Water level from floor:570 mm, 1 mm increase since 7:00 on June 25)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 9:43 on June 19)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 12:02 on June 7)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	Transfer Completed	(From 9:30 on June 25 to 16:30 on June 25)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 11:48 on June 20   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.