

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on June 27)**

Water Level of the accumulated water (at 7:00 on June 27)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,996 mm (55 mm increase since 16:00 on June 26)	O.P.+ 2,997 mm (14 mm decrease since 16:00 on June 26)	—
	Water level of Turbine Building	O.P.+ 2,848 mm (3 mm increase since 16:00 on June 26)	O.P.+ 2,943 mm (48 mm increase since 16:00 on June 26)	O.P.+ 2,860 mm (32 mm decrease since 16:00 on June 26)	O.P.+ 2,870 mm (2 mm decrease since 16:00 on June 26)
	Water level of Reactor Building	O.P.+ 4,265 mm (46 mm increase since 16:00 on June 26)	O.P.+ 3,245 mm (48 mm increase since 16:00 on June 26)	O.P.+ 3,097 mm (33 mm decrease since 16:00 on June 26)	O.P.+ 2,877 mm (3 mm increase since 16:00 on June 26)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,577 mm (Increase from initial level:5,794 mm, 3 mm increase since 16:00 on June 26) O.P.+ 1,289 mm (Increase from initial level:2,015 mm, 26 mm decrease since 16:00 on June 26) O.P.+ 4,368 mm (Water level from floor:572 mm, 2 mm increase since 16:00 on June 26)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:00 on June 26)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:28 on March 21 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:24 on June 27 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	- At 8:24 AM on June 27, we temporarily stopped the second Cesium Adsorption Apparatus (SARRY) for a filter cleaning.				

※ For quick publication of the data of water level, values are provided as reference values.