

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 18:00 on June 28)**

Water Level of the accumulated water (at 16:00 on June 28)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,097 mm (26 mm increase since 7:00 on June 28)	O.P.+ 2,965 mm (8 mm decrease since 7:00 on June 28)	—
	Water level of Turbine Building	O.P.+ 2,860 mm (5 mm increase since 7:00 on June 28)	O.P.+ 3,029 mm (21 mm increase since 7:00 on June 28)	O.P.+ 2,805 mm (11 mm decrease since 7:00 on June 28)	O.P.+ 2,844 mm (8 mm decrease since 7:00 on June 28)
	Water level of Reactor Building	O.P.+ 4,308 mm (9 mm increase since 7:00 on June 28)	O.P.+ 3,325 mm (22 mm increase since 7:00 on June 28)	O.P.+ 3,035 mm (18 mm decrease since 7:00 on June 28)	O.P.+ 2,855 mm (7 mm decrease since 7:00 on June 28)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,293 mm (Increase from initial level:5,510 mm, 95 mm decrease since 7:00 on June 28) O.P.+ 1,840 mm (Increase from initial level:2,566 mm, 126 mm increase since 7:00 on June 28) O.P.+ 4,368 mm (Water level from floor:572 mm, No change since 7:00 on June 28)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:00 on June 26)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	Transfer Completed	(From 10:15 on June 28 to 16:00 on June 28)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 16:30 on June 27 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 12:39 on June 27 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.