

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on July 1)**

Water Level of the accumulated water (at 7:00 on July 1)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,258 mm (35 mm increase since 16:00 on June 30)	O.P.+ 2,897 mm (17 mm decrease since 16:00 on June 30)	—
	Water level of Turbine Building	O.P.+ 2,875 mm (3 mm increase since 16:00 on June 30)	O.P.+ 3,170 mm (32 mm increase since 16:00 on June 30)	O.P.+ 2,722 mm (19 mm decrease since 16:00 on June 30)	O.P.+ 2,780 mm (16 mm decrease since 16:00 on June 30)
	Water level of Reactor Building	O.P.+ 4,369 mm (15 mm increase since 16:00 on June 30)	O.P.+ 3,466 mm (33 mm increase since 16:00 on June 30)	O.P.+ 2,953 mm (18 mm decrease since 16:00 on June 30)	O.P.+ 2,797 mm (15 mm decrease since 16:00 on June 30)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,666 mm (Increase from initial level:4,883 mm, 142 mm decrease since 16:00 on June 30) O.P.+ 2,716 mm (Increase from initial level:3,442 mm, 210 mm increase since 16:00 on June 30) O.P.+ 4,370 mm (Water level from floor:574 mm, 1 mm increase since 16:00 on June 30)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:00 on June 26)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 16:30 on June 27 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 12:39 on June 27 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.