

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on July 2)**

Water Level of the accumulated water (at 7:00 on July 2)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,316 mm (35 mm increase since 16:00 on July 1)	O.P.+ 2,871 mm (17 mm decrease since 16:00 on July 1)	—
	Water level of Turbine Building	O.P.+ 2,880 mm (3 mm increase since 16:00 on July 1)	O.P.+ 3,221 mm (31 mm increase since 16:00 on July 1)	O.P.+ 2,696 mm (18 mm decrease since 16:00 on July 1)	O.P.+ 2,754 mm (17 mm decrease since 16:00 on July 1)
	Water level of Reactor Building	O.P.+ 4,391 mm (15 mm increase since 16:00 on July 1)	O.P.+ 3,516 mm (29 mm increase since 16:00 on July 1)	O.P.+ 2,922 mm (18 mm decrease since 16:00 on July 1)	O.P.+ 2,773 mm (14 mm decrease since 16:00 on July 1)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,447 mm (Increase from initial level:4,664 mm, 135 mm decrease since 16:00 on July 1) O.P.+ 3,104 mm (Increase from initial level:3,830 mm, 253 mm increase since 16:00 on July 1) O.P.+ 4,371 mm (Water level from floor:575 mm, No change since 16:00 on July 1)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:00 on June 26)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 16:30 on June 27 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 12:39 on June 27 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.