

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 18:00 on July 2)**

Water Level of the accumulated water (at 16:00 on July 2)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,303 mm (13 mm decrease since 7:00 on July 2)	O.P.+ 2,867 mm (4 mm decrease since 7:00 on July 2)	—
	Water level of Turbine Building	O.P.+ 2,881 mm (1 mm increase since 7:00 on July 2)	O.P.+ 3,208 mm (13 mm decrease since 7:00 on July 2)	O.P.+ 2,710 mm (14 mm increase since 7:00 on July 2)	O.P.+ 2,745 mm (9 mm decrease since 7:00 on July 2)
	Water level of Reactor Building	O.P.+ 4,400 mm (9 mm increase since 7:00 on July 2)	O.P.+ 3,519 mm (3 mm increase since 7:00 on July 2)	O.P.+ 2,935 mm (13 mm increase since 7:00 on July 2)	O.P.+ 2,764 mm (9 mm decrease since 7:00 on July 2)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,384 mm (Increase from initial level:4,601 mm, 63 mm decrease since 7:00 on July 2) O.P.+ 3,272 mm (Increase from initial level:3,998 mm, 168 mm increase since 7:00 on July 2) O.P.+ 4,371 mm (Water level from floor:575 mm, No change since 7:00 on July 2)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:08 on July 2)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:00 on June 26)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	Transfer Completed	(From 10:00 on July 2 to 15:00 on July 2)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 16:30 on June 27 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 12:39 on June 27 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.