

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 18:00 on July 3)**

Water Level of the accumulated water (at 16:00 on July 3)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,229 mm (24 mm decrease since 7:00 on July 3)	O.P.+ 2,880 mm (3 mm increase since 7:00 on July 3)	—
	Water level of Turbine Building	O.P.+ 2,884 mm (1 mm increase since 7:00 on July 3)	O.P.+ 3,144 mm (21 mm decrease since 7:00 on July 3)	O.P.+ 2,749 mm (1 mm decrease since 7:00 on July 3)	O.P.+ 2,746 mm (4 mm increase since 7:00 on July 3)
	Water level of Reactor Building	O.P.+ 4,413 mm (3 mm increase since 7:00 on July 3)	O.P.+ 3,462 mm (22 mm decrease since 7:00 on July 3)	O.P.+ 2,979 mm (4 mm increase since 7:00 on July 3)	O.P.+ 2,759 mm (3 mm increase since 7:00 on July 3)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,317 mm (Increase from initial level:4,534 mm, 22 mm increase since 7:00 on July 3) O.P.+ 3,523 mm (Increase from initial level:4,249 mm, 33 mm decrease since 7:00 on July 3) O.P.+ 4,372 mm (Water level from floor:576 mm, 1 mm increase since 7:00 on July 3)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:08 on July 2)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:22 on July 3)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	Transfer Completed	(From 10:00 on July 3 to 15:00 on July 3)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 16:30 on June 27 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 12:39 on June 27 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	*From 14:00 on June 26 to 9:49 on July 3, we transferred accumulated water from the basement of the Unit 3 Turbine building to the Central Radioactive Waste Treatment Facility (High Temperature Incinerator Building). We started transferring it to the Central Radioactive Waste Treatment Facility (Process Main Building) at 10:22 on July 3.				

※ For quick publication of the data of water level, values are provided as reference values.