

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on July 4)**

Water Level of the accumulated water (at 7:00 on July 4)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,190 mm (39 mm decrease since 16:00 on July 3)	O.P.+ 2,877 mm (3 mm decrease since 16:00 on July 3)	—
	Water level of Turbine Building	O.P.+ 2,887 mm (3 mm increase since 16:00 on July 3)	O.P.+ 3,110 mm (34 mm decrease since 16:00 on July 3)	O.P.+ 2,745 mm (4 mm decrease since 16:00 on July 3)	O.P.+ 2,746 mm (No change since 16:00 on July 3)
	Water level of Reactor Building	O.P.+ 4,424 mm (11 mm increase since 16:00 on July 3)	O.P.+ 3,430 mm (32 mm decrease since 16:00 on July 3)	O.P.+ 2,971 mm (8 mm decrease since 16:00 on July 3)	O.P.+ 2,761 mm (2 mm increase since 16:00 on July 3)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,441 mm (Increase from initial level:4,658 mm, 124 mm increase since 16:00 on July 3) O.P.+ 3,317 mm (Increase from initial level:4,043 mm, 206 mm decrease since 16:00 on July 3) O.P.+ 4,372 mm (Water level from floor:576 mm, No change since 16:00 on July 3)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:08 on July 2)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:22 on July 3)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 16:30 on June 27 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 12:39 on June 27 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.