Situation of water level, transfer and treatment of the accumulated water in Fukushima Daiichi Nuclear Power Station (at 18:00 on July 4)

		Unit 1	Unit 2	Unit 3	Unit 4
Water Level of the accumulated water (at 16:00 on July 4)	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,168 mm (22 mm decrease since 7:00 on July 4)	O.P.+ 2,877 mm (No change since 7:00 on July 4)	—
	Water level of Turbine Building	O.P.+ 2,888 mm (1 mm increase since 7:00 on July 4)	O.P.+ 3,092 mm (18 mm decrease since 7:00 on July 4)	O.P.+ 2,737 mm (8 mm decrease since 7:00 on July 4)	O.P.+ 2,744 mm (2 mm decrease since 7:00 on July 4)
	Water level of Reactor Building	O.P.+ 4,423 mm (1 mm decrease since 7:00 on July 4)	O.P.+ 3,412 mm (18 mm decrease since 7:00 on July 4)	O.P.+ 2,969 mm (2 mm decrease since 7:00 on July 4)	O.P.+ 2,760 mm (1 mm decrease since 7:00 on July 4)
	Water level of each building in the Centralized Radiation Waste	Process Main Building	O.P.+ 3.543 mm (Increase from initial level:4.760 mm, 102 mm increase since 7:00 on July 4)		
		High Temperature Incinerator Building	O.P.+ 3,199 mm (Increase from initial level:3,925 mm, 118 mm decrease since 7:00 on July 4)		
Treatment Fa		On-site Bunker Building	O.P.+ 4,372 mm (Water level from floor:576 mm, No change since 7:00 on July 4)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		_	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:08 on July 2)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:22 on July 3)	_
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	Transfer Completed	(From 10:00 on July 4 to 15:00 on July 4)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 16:30 on June 27 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 12:39 on June 27 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

% For quick publication of the data of water level, values are provided as reference values.