

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on July 5)**

Water Level of the accumulated water (at 7:00 on July 5)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,131 mm (37 mm decrease since 16:00 on July 4)	O.P.+ 2,875 mm (2 mm decrease since 16:00 on July 4)	—
	Water level of Turbine Building	O.P.+ 2,891 mm (3 mm increase since 16:00 on July 4)	O.P.+ 3,060 mm (32 mm decrease since 16:00 on July 4)	O.P.+ 2,736 mm (1 mm decrease since 16:00 on July 4)	O.P.+ 2,742 mm (2 mm decrease since 16:00 on July 4)
	Water level of Reactor Building	O.P.+ 4,414 mm (9 mm decrease since 16:00 on July 4)	O.P.+ 3,381 mm (31 mm decrease since 16:00 on July 4)	O.P.+ 2,963 mm (6 mm decrease since 16:00 on July 4)	O.P.+ 2,758 mm (2 mm decrease since 16:00 on July 4)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,711 mm (Increase from initial level:4,928 mm, 168 mm increase since 16:00 on July 4) O.P.+ 3,010 mm (Increase from initial level:3,736 mm, 189 mm decrease since 16:00 on July 4) O.P.+ 4,372 mm (Water level from floor:576 mm, No change since 16:00 on July 4)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:08 on July 2)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:22 on July 3)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 16:30 on June 27 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 12:39 on June 27 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.