

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on July 5)**

Water Level of the accumulated water (at 16:00 on July 5)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,111 mm (20 mm decrease since 7:00 on July 5)	O.P.+ 2,874 mm (1 mm decrease since 7:00 on July 5)	—
	Water level of Turbine Building	O.P.+ 2,893 mm (2 mm increase since 7:00 on July 5)	O.P.+ 3,043 mm (17 mm decrease since 7:00 on July 5)	O.P.+ 2,733 mm (3 mm decrease since 7:00 on July 5)	O.P.+ 2,741 mm (1 mm decrease since 7:00 on July 5)
	Water level of Reactor Building	O.P.+ 4,407 mm (7 mm decrease since 7:00 on July 5)	O.P.+ 3,365 mm (16 mm decrease since 7:00 on July 5)	O.P.+ 2,963 mm (No change since 7:00 on July 5)	O.P.+ 2,755 mm (3 mm decrease since 7:00 on July 5)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,808 mm (Increase from initial level:5,025 mm, 97 mm increase since 7:00 on July 5) O.P.+ 2,916 mm (Increase from initial level:3,642 mm, 94 mm decrease since 7:00 on July 5) O.P.+ 4,374 mm (Water level from floor:578 mm, 2 mm increase since 7:00 on July 5)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:08 on July 2)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:22 on July 3)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 16:30 on June 27 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 12:39 on June 27 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.