

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on July 8)**

Water Level of the accumulated water (at 7:00 on July 8)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,968 mm (34 mm decrease since 16:00 on July 7)	O.P.+ 2,886 mm (16 mm increase since 16:00 on July 7)	—
	Water level of Turbine Building	O.P.+ 2,900 mm (1 mm increase since 16:00 on July 7)	O.P.+ 2,921 mm (28 mm decrease since 16:00 on July 7)	O.P.+ 2,756 mm (20 mm increase since 16:00 on July 7)	O.P.+ 2,739 mm (7 mm increase since 16:00 on July 7)
	Water level of Reactor Building	O.P.+ 4,310 mm (27 mm decrease since 16:00 on July 7)	O.P.+ 3,246 mm (25 mm decrease since 16:00 on July 7)	O.P.+ 2,989 mm (28 mm increase since 16:00 on July 7)	O.P.+ 2,751 mm (5 mm increase since 16:00 on July 7)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,039 mm (Increase from initial level:5,256 mm, 163 mm decrease since 16:00 on July 7) O.P.+ 2,824 mm (Increase from initial level:3,550 mm, 217 mm increase since 16:00 on July 7) O.P.+ 4,375 mm (Water level from floor:579 mm, 1 mm increase since 16:00 on July 7)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:08 on July 2)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:05 on July 7)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 16:30 on June 27 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 8:53 on July 8 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	* 2nd Cesium Absorption Apparatus (SARRY) was stopped at 8:53 am on July 8 due to a filter cleaning.				

※ For quick publication of the data of water level, values are provided as reference values.