

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on July 9)**

Water Level of the accumulated water (at 7:00 on July 9)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,920 mm (30 mm decrease since 16:00 on July 8)	O.P.+ 2,907 mm (13 mm increase since 16:00 on July 8)	—
	Water level of Turbine Building	O.P.+ 2,903 mm (2 mm increase since 16:00 on July 8)	O.P.+ 2,879 mm (26 mm decrease since 16:00 on July 8)	O.P.+ 2,778 mm (15 mm increase since 16:00 on July 8)	O.P.+ 2,754 mm (10 mm increase since 16:00 on July 8)
	Water level of Reactor Building	O.P.+ 4,291 mm (9 mm decrease since 16:00 on July 8)	O.P.+ 3,204 mm (26 mm decrease since 16:00 on July 8)	O.P.+ 3,006 mm (14 mm increase since 16:00 on July 8)	O.P.+ 2,765 mm (10 mm increase since 16:00 on July 8)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,809 mm (Increase from initial level:5,026 mm, 139 mm decrease since 16:00 on July 8) O.P.+ 3,301 mm (Increase from initial level:4,027 mm, 258 mm increase since 16:00 on July 8) O.P.+ 4,376 mm (Water level from floor:580 mm, 1 mm increase since 16:00 on July 8)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:08 on July 2)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:05 on July 7)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 16:30 on June 27 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 12:11 on July 8 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.