

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on July 9)**

Water Level of the accumulated water (at 16:00 on July 9)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,937 mm (17 mm increase since 7:00 on July 9)	O.P.+ 2,913 mm (6 mm increase since 7:00 on July 9)	—
	Water level of Turbine Building	O.P.+ 2,904 mm (1 mm increase since 7:00 on July 9)	O.P.+ 2,895 mm (16 mm increase since 7:00 on July 9)	O.P.+ 2,780 mm (2 mm increase since 7:00 on July 9)	O.P.+ 2,762 mm (8 mm increase since 7:00 on July 9)
	Water level of Reactor Building	O.P.+ 4,283 mm (8 mm decrease since 7:00 on July 9)	O.P.+ 3,204 mm (No change since 7:00 on July 9)	O.P.+ 3,012 mm (6 mm increase since 7:00 on July 9)	O.P.+ 2,770 mm (5 mm increase since 7:00 on July 9)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,722 mm (Increase from initial level:4,939 mm, 87 mm decrease since 7:00 on July 9) O.P.+ 3,284 mm (Increase from initial level:4,010 mm, 17 mm decrease since 7:00 on July 9) O.P.+ 4,376 mm (Water level from floor:580 mm, No change since 7:00 on July 9)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Transfer Completed (From 10:08 on July 2 to 10:08 on July 9)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Transfer Completed (From 10:05 on July 7 to 10:28 on July 9)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 16:30 on June 27 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 12:11 on July 8 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.