

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on July 10)**

Water Level of the accumulated water (at 16:00 on July 10)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,020 mm (29 mm increase since 7:00 on July 10)	O.P.+ 2,926 mm (4 mm increase since 7:00 on July 10)	—
	Water level of Turbine Building	O.P.+ 2,908 mm (1 mm increase since 7:00 on July 10)	O.P.+ 2,966 mm (26 mm increase since 7:00 on July 10)	O.P.+ 2,797 mm (6 mm increase since 7:00 on July 10)	O.P.+ 2,777 mm (6 mm increase since 7:00 on July 10)
	Water level of Reactor Building	O.P.+ 4,278 mm (No change since 7:00 on July 10)	O.P.+ 3,271 mm (26 mm increase since 7:00 on July 10)	O.P.+ 3,029 mm (6 mm increase since 7:00 on July 10)	O.P.+ 2,784 mm (6 mm increase since 7:00 on July 10)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,506 mm (Increase from initial level:4,723 mm, 72 mm decrease since 7:00 on July 10) O.P.+ 2,950 mm (Increase from initial level:3,676 mm, 118 mm decrease since 7:00 on July 10) O.P.+ 4,377 mm (Water level from floor:581 mm, No change since 7:00 on July 10)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	—	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 16:30 on June 27 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 12:11 on July 8 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.