

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on July 11)**

Water Level of the accumulated water (at 7:00 on July 11)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,066 mm (75 mm increase since 16:00 on July 10)	O.P.+ 2,935 mm (13 mm increase since 16:00 on July 10)	—
	Water level of Turbine Building	O.P.+ 2,909 mm (2 mm increase since 16:00 on July 10)	O.P.+ 3,005 mm (65 mm increase since 16:00 on July 10)	O.P.+ 2,808 mm (17 mm increase since 16:00 on July 10)	O.P.+ 2,787 mm (16 mm increase since 16:00 on July 10)
	Water level of Reactor Building	O.P.+ 4,284 mm (6 mm increase since 16:00 on July 10)	O.P.+ 3,310 mm (65 mm increase since 16:00 on July 10)	O.P.+ 3,042 mm (19 mm increase since 16:00 on July 10)	O.P.+ 2,792 mm (14 mm increase since 16:00 on July 10)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,386 mm (Increase from initial level:4,603 mm, 192 mm decrease since 16:00 on July 10) O.P.+ 2,779 mm (Increase from initial level:3,505 mm, 289 mm decrease since 16:00 on July 10) O.P.+ 4,377 mm (Water level from floor:581 mm, No change since 16:00 on July 10)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	—	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 16:30 on June 27 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 12:11 on July 8 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.