

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 18:00 on July 12)**

Water Level of the accumulated water (at 16:00 on July 12)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 3,155 mm (26 mm increase since 7:00 on July 12)	O.P.+ 2,912 mm (11 mm decrease since 7:00 on July 12)	—
	Water level of Turbine Building	O.P.+ 2,914 mm (1 mm increase since 7:00 on July 12)	O.P.+ 3,082 mm (19 mm increase since 7:00 on July 12)	O.P.+ 2,759 mm (14 mm decrease since 7:00 on July 12)	O.P.+ 2,787 mm (6 mm decrease since 7:00 on July 12)
	Water level of Reactor Building	O.P.+ 4,311 mm (8 mm increase since 7:00 on July 12)	O.P.+ 3,386 mm (21 mm increase since 7:00 on July 12)	O.P.+ 2,995 mm (17 mm decrease since 7:00 on July 12)	O.P.+ 2,797 mm (5 mm decrease since 7:00 on July 12)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 3,387 mm (Increase from initial level:4,604 mm, 19 mm increase since 7:00 on July 12) O.P.+ 2,442 mm (Increase from initial level:3,168 mm, 93 mm decrease since 7:00 on July 12) O.P.+ 4,378 mm (Water level from floor:582 mm, No change since 7:00 on July 12)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 15:12 on July 11)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 16:30 on June 27 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 12:11 on July 8 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.